



Government Of West Bengal
Office Of The Divisional Fire Officer,Paschim Bardhaman
West Bengal Fire & Emergency Services
Bhangakhuti, Purba Burdwan, P.O.:- Rajbati, Pin :- 713104

Memo no.:IND/WB/FES/20192020/63926

Date: 30-06-2023

From:

Divisional Fire Officer,Paschim Bardhaman
West Bengal Fire & Emergency Services

To: ST JUDES HIGH SCHOOL PRISCILLA VAZ TRUST.

RIVERSIDE BURNPUR KALAJHARIA PIPE LINE , R.S.PLOT.NO.262/1092(P), KH.NO.287, J.L.NO-26, MOUZA-KALAJHARIA, P.S.-HIRAPUR, PIN-713325, DIST-PASCHIM BARDHAMAN, UNDER -A.M.C.

Sub: Renewal of Fire Safety Certificate for the existing construction of G+3 storied building under group educational, in favour of 'ST JUDES HIGH SCHOOL PRISCILLA VAZ TRUST', at the Premises no. Riverside Burnpur Kalajharia Pipe Line , R.S.Plot.No. 262/1092(P), Kh.No.287, J.L.No-26, Mouza-Kalajharia, Under -A.M.C., P.S.-Hirapur, Dist-Paschim Bardhaman PIN 713325.

This is in reference to your application no. 0125191239100159 dated 23-03-2023 regarding the Renewal of Fire Safety Certificate for the existing construction of G+3 storied building under group educational, in favour of 'ST JUDES HIGH SCHOOL PRISCILLA VAZ TRUST', at the Premises no. Riverside Burnpur Kalajharia Pipe Line , R.S.Plot.No. 262/1092(P), Kh.No.287, J.L.No-26, Mouza-Kalajharia, Under -A.M.C., P.S.-Hirapur, Dist-Paschim Bardhaman PIN 713325.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1.One Stand by Fire Pump should be arranged with the down comer system within one month.
- 2.Driveway must be free from any type of obstruction for easy movement of fire appliances.
No parking will be allowed on the drive way.
- 3.To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be maintained strictly.
- 4.Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them,

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191239100159.

Page : 1

PRINCIPAL
ST. JUDE'S HIGH SCHOOL
KALAJHARIA / BURNPUR

MANAGER
ST. JUDE'S HIGH SCHOOL
KALAJHARIA, BURNPUR.

Powered By **emSigner** For secure paperless solutions
Please visit www.emsigner.com

particularly lines above false ceiling and ducts.

5. A fire control room including a closed circuit TV system will have to be maintained which observe all floor of the building.
 6. The notice of fire fighting and evacuation plan from the building shall be prepared and displayed at all suitable places of the building.
 7. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
 8. Mock Fire practice and evacuation drill shall be performed periodically with participation of all Teaching, Non- Teaching employees and students of the building.
 9. A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.
 10. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
 11. The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
 12. Adequate nos. of Fire Safety Directional Signage's Board and Assembly Point shall be prepared and be displayed at all appropriate places of the building.
 13. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
 14. Directional sign of escape route shall be displayed prominently.
 15. This Fire Safety certificate is valid for three years and has to be renewed every three years from the date of issue of this letter.
- Any deviation and changes the nature of the use of the building in respect of submitted plan drawing, without obtaining prior permission from the office, the RFSC shall be treated cancelled.

Signature valid

Digitally signed by SHYAM
CHANDRA CHODAL
Date: 2023.07.24 16:18:11 IST

Divisional Fire Officer, Paschim Bardhaman
West Bengal Fire & Emergency Services

S. Mitra
PRINCIPAL
ST. JUDE'S HIGH SCHOOL
KALAJHARIA / BURNPUR

Heu's
MANAGER
ST. JUDE'S HIGH SCHOOL
KALAJHARIA, BURNPUR.