

PASCHIM BARDHAMAN WATER TESTING DISTRICT LABORATORY

ISMILE (WEST), VIVEKANANDA PALLY, ASANSOL - 713301

Phone & Fax - 0341 2284210, E-mail: ee_rcfa_d1@wbphed.gov.in,

Asansol PHE Office (R.C.F.A.Div-I) Laboratory, E-mail: rcfalabasansol@gmail.com

Paschim Bardhaman,



Results of Physical Chemical & Bacteriological analysis of water sample

Water sample of ----- ST. JUDE'S HIGH SCHOOL, KALAJHARIA PIPELINE ROAD, BURNPUR,
PASCHIM BADHAMAN

Sample received from----- SAMPLE WATER OF PURIFIER

Sample Collected by----- CONCERN AUTHORITY

Sample Submitted by----- CONCERN AUTHORITY

Sample received on ----- 18/05/2025 2026 *PC*

Test Completion Date ----- 19/05/2025 2026 *PC*

Sample reference no ----- 11 /216/LAB-2026 /RCD-I

GRN NO:-----192026270050064198

MEMO NO-----N.A

Sample Tested as Received

Parameters	Observed Values	Limits as par IS 10500-2012 (Second revision)	
		Acceptable limit	Permissible limit
Physical Analysis			
pH value	7.67	6.5 to 8.5	6.5 to 8.5
Turbidity (NTU)	0.57	1	5
Total Dissolved Solids (mg/l)	208.00	500	2000
Total Hardness as CaCO ₃ (mg/l)	84.00	200	600
Chemical Analysis			
Iron (as Fe) mg/l	0.006	1.0	No Relaxation
Manganese(mg/L)	-	0.10	0.30
Residual Chlorine	-	0.2	1.0
Bacteriological Analysis			
Total Coliform Count (CFU/100ML)	0	0	0
E.coli Count (Faecal Coliform) (CFU/100ML)	0	0	0

[Signature]
Chemist

Paschim Barddhaman Water
Testing District Laboratory

[Signature]
Bacteriologist

Paschim Barddhaman water
Testine District Laboratory

**Above the permissible limit*

[Signature]
Assistant Engineer -I
RCEA Div-I, Asansol
P.H.E.Dte.

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by ...MUKUL HAZARI (Bacteriologist)

(Name of Officers with designation) from P.B.W.T.D.L. BCFADIV-I, PHED

inspected the ...ST. JUDE'S HIGH SCHOOL, KALAJHARIA

(Name & Address of the school) on 18/05/26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. RCD-2/LAB-216 dated 19/05/26

of P.B.W.T.D.L. (PHED Lab) certified that

the ST. JUDE'S HIGH SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 1 year (19/05/27)

Signature with Seal:

Name

Designation

Name & Address of the Office / Department: P.I.E.

18/5/2026

Kashinath Roy

Assistant Engineer

To

ST. JUDE'S HIGH SCHOOL, KALAJHARIA

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies